



1525 Hanover Street
 Hanover, MA 02339
 Phone 781-826-9755
 Fax 781-829-0240

www.aircleaningspecialistsne.com

of New England LLC

Preventive Maintenance and Service of Source Capture Vehicle Exhaust Removal System

| Customer: | Fire Department Locations: | Vehicles |
|-------------------------------|---|----------|
| Central Falls Fire Department | Headquarters Station - 150 Illinois St. | 4 |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

| | |
|---------------|-----------------------|
| Install Date: | Warranty Expire Date: |
| | |

| | |
|----------------------|-----------------------|
| Contract Start Date: | Contract Expire Date: |
| November 1, 2019 | October 31, 2020 |

Per station cost of service is \$160.00 initial vehicle, \$136.00 per additional vehicle attached to the Source Capture Vehicle Exhaust Removal System.

| Total Number of Vehicles: | Frequency of Service: | Annual Cost of Service: |
|---------------------------|-----------------------|-------------------------|
| Four (4) Vehicles | Every six (6) months | \$1,136.00 |

All prices are for service contract only and do not include parts out of warranty. For service contracts there will be a service charge of \$195.00. All prices are for service only and do not include parts out of warranty.

As a Service Contract Customer all non warranty parts are discounted 6%.

Maintenance program applies to the items specified below.

C:\Users\chiefbradley.CENTRALFALLSRI\AppData\Local\Microsoft\Windows\Temporary Internet Files\Content.Outlook\3UO7HCTW\Central Falls RI DOC

RECEIVED
 CENTRAL FALLS
 FIRE DEPT.
 DATE 1/15/20 BY



1525 Hanover Street
 Hanover, MA 02339
 Phone 781-826-9755
 Fax 781-829-0240

www.aircleaningspecialistsne.com

of New England LLC

Preventive Maintenance and Service of Source Capture Vehicle Exhaust Removal System

Hose Inspection

Hose clearance from ground
 Hose alignment
 Hose Condition

Nozzle Inspection

Attachment on tailpipe
 Air line attachment to MFD Valve
 Nozzle condition

Safety Disconnect Inspection

Rubber seal
 Aluminum fittings
 Debris screen

Track & Hardware Inspection

Supports & hardware
 Track cleaning
 End stops
 Trolley condition & adjustments
 Balancer tension & adjustments

Compressed Air Supply Inspection

Regulator condition & adjustment
 Air line and fittings
 Uncoupling Valve
 Manual fill valve
 Dryer

Air Compressor Inspection

Drain tank
 Check oil
 Belt
 Regulator
 Check Pressure

Blower Inspection

Lubricate motor
 Disconnect switch at fan

Ductwork System Inspection

Joints and supports
 Stack and discharge cap

Control Panel Inspection

Timer
 Sensor condition & adjustments
 Control relays
 Fuses

Date Submitted: _____
 Submitted By: CM Rake
 Air Cleaning Specialists
 Date Accepted: 1/14/2020
 Accepted By: [Signature]
 Printed Name: James A. Diossa

C:\Users\chiefbradley.CENTRALFALLSRI\AppData\Local\Microsoft\Windows\Temporary Internet Files\Content.Outlook\3UO7HCTW\Central Falls RI.DOC

Approved as to form and correctness:

[Signature]

[Signature]
 Barbara J. Addison
 Director of Finance