

Heritage Wind Project

Case No. 16-F-0546

1001.38 Exhibit 38

Water Interconnection

EXHIBIT 38 WATER INTERCONNECTION

In general, the proposed Facility is not expected to require water interconnection facilities. As a result, the requirements of 16 NYCRR § 1001.38 are not applicable to the majority of the Facility components. However, the O&M Building will require potable water. Although the O&M Building is located within a local water district, there is no local water line available for interconnection. The property upon which the O&M Building is proposed is currently served by a private water well. The Applicant is proposing to connect to the existing water well to serve the limited potable needs for the O&M Building. The well interconnection at the O&M Building will be engineered in accordance with the standards set forth in 10 NYCRR Part 75, Standards for Individual Onsite Water Supply Systems. If, prior to construction of the Facility, the water district installs a water line adjacent to the O&M Building, the Applicant will interconnect to the water line per local code.

Any surface or ground water withdrawal system used to supply water for the proposed concrete batch plant will have a withdrawal capacity of less than 100,000 gallons per day. As a result, no water withdrawal permit will be required under 6 NYCRR Part 601. Please refer to Exhibit 23 for additional information.